

Test report

Testing of separation efficiency of MobileGo/MonoGo

According to EN-ISO-15012-1:2013

Test location: Plymovent Group BV Koraalstraat 9 1812 RK Alkmaar, NL

Test performed by:G. De VriesTest date :12-09-2017Report by:J. Crezee

Table of content

1.	General introduction						
2.	Introduction to MobileGo and MonoGo						
2	2.1 Functional description of the filter units5						
3.	ment performance	7					
3	.1	Gen	eral test setup and procedure	7			
3	.2	Test	setup in practice	8			
	3.2.	1	Setup to determine welding fume generation rate	8			
	3.2.	2	Setup to determine the filter unit separation efficiency	9			
	3.2.	3	Sample taking of filtered air	10			
	3.2.	4	Airflow measurements and logging	10			
	3.2.	5	Other practical information	10			
4.	Mea	sure	ment results	12			
4	.1	Test	1	12			
	4.1.	1	Welding parameters	12			
	4.1.	2	Determination of Fume Generation Rate	13			
	4.1.	3	Determination of parameter for efficiency calculation	13			
	4.1.4	4	Efficiency calculation	14			
4	.2	Test	2	14			
	4.2.	1	Welding parameters	14			
	4.2.	2	Determination of Fume Generation Rate	15			
	4.2.	3	Determination of parameter for efficiency calculation	15			
	4.2.	4	Efficiency calculation	16			
5.	Calc	ulatio	on of final results and conclusion	17			
5	.1	Avei	age efficiency	17			
5	.2	95%	one-sided confidence interval	17			
5	.3	Low	er confidence limit value	17			
5	.4	Con	clusion	17			
6.	Lite	rature	2	18			
Арр	endi	(A: P	roduct Data Sheet of the MobileGo Extraction unit	19			
Арр	Appendix B: Product Data Sheet of the MonoGo Extraction unit						
Арр	Appendix C: Result weight determination sample filter test 1						
٨٥٢	endix	D: R	esult weight determination sample filter test 2	26			

Appendix E: Calibration certificate of pressure monitor 1	. 27
Appendix F: Calibration certificate of pressure monitor 2	. 28
Appendix G: Calibration certificate of precision scale	. 29

1. General introduction

Plymovent is a global manufacturer of solutions for clean air at work. Plymovent offers solutions for three industrial segments: (1) welding fume, (2) oilmist and (3) exhaust extraction.

For welding fume, Plymovent offers a broad range of products and solutions to capture, transport and filter welding fumes. The products in this portfolio range from small mobile extraction units with disposable filter, up to centralized filter installations capable of handling air volumes up to 60.000 m³/h.

In order to fulfill customer demands, and to be able to offer solutions for the extraction of high alloy welding fumes, Plymovent develops filter units with high efficiency filter, which are designed to comply with the W3 requirements as determined under a ISO 15012-1:2013.

This report describes the test procedure, results and forthcoming conclusion of the MobileGo being tested according this standard, and where conformity of the results is also claimed for the MonoGo, which is a product variant of the MobileGo.

2. Introduction to MobileGo and MonoGo

The MobileGo and MonoGo are fume extraction units, which are designed for occasional use, also refer to Figure 2-1. Both models are product variant, and both contain the same set of filters and interior construction.

The unit can handle welding fumes generated by common manual welding processes, such as MIG, TIG and electrode welding.



Figure 2-1 Image of the Plymovent MobileGo (left), and MonoGo (right) extraction units

2.1 Functional description of the filter units

As described before, MobileGo and MonoGo are build identical. The difference is in the application. The MobileGo features a set of wheels, so it can be used as a mobile extraction unit. The MonoGo does not have wheels, but can be mounted to a structure, such as a wall or stand.

The unit contains a 2 stage filter package, a built in fan and basic controls.

The unit functions by having a fan wheel create a negative pressure. Air is being extracted through a movable extraction arm, into a 2 stage filter package. The first filter the extracted fumes pass is a coarse prefilter. This filter is designed to separate course particles. This filter is a 1 m² polyester prefilter with a efficiency of ISO Coarse 70% according to ISO 16890.

The second filter the extracted fumes pass, is a glass fiber main filter, with a surface area of 15 m². The efficiency of this filter is E12 according to EN 1822-1:2009.

Both the prefilter and the mainfilter are disposable filters – they are not intended to be cleaned and/or reused.

After the extracted air passes the filters and the fan, the air is being exhausted at the backside of the filter unit (MobileGo) or the topside (MonoGo).

To safeguard proper extraction capacity, the unit has a build in pressure switch, which monitor the pressure drop over the filter package. When the pressure drop reaches a preset level, an audio signal is being generated.


The minimum airflow of the MobileGo and MonoGo is prescribed by Plymovent at 500 m³/h.

All relevant technical data is given in Appendix A: Product Data Sheet of the MobileGo Extraction unit., on page 19 and Appendix B: Product Data Sheet of the MonoGo Extraction unit, on page 22.

3. Measurement performance

3.1 General test setup and procedure

To assess the fume separation efficiency, the test setup as shown in Figure 3-1 is used.



Key

- 1 welding fume source (see Figure B.1)
- 2 welding fume separation equipment
- 3 test cabin with funnel shaped outlet
- 4 air mover
- 5 position for measuring the air flow rate in the upstream duct, $q_{V, 1}$
- 6 positions for measuring the air flow rate in the downstream duct, $q_{V, 2}$ and isokinetic sampling of welding fume in the downstream duct
- 7 damper (to control the air flow rate passing through the welding fume source in order to avoid shielding gas disturbance)
- 8 damper (to ensure that all welding fume is captured, even when filter units with a low air flow rate are under test)
- 9 damper (to regulate the total air flow rate passing through the separation equipment)
- 10 damper (to control the air flow rate in the downstream duct in order to achieve a slight overpressure in the cabin)
- 11 gap with a flap (to prevent damage on the cabin in case of high overpressure)
- d1 upstream duct diameter
- d2 downstream duct diameter

Figure 3-1 - Schematic layout of test setup (source: standard NEN-EN-ISO 15012-1:2013)

To determine the filtration efficiency of a filter unit, first the fume rate of a welding fume generator is determined, in accordance to EN-ISO 15011-1. The scale used to determine the weight of the filter before and after welding is a Kern EG 220-3NM. This scale complies with the demands as prescribed in to EN-ISO 15011-1. The calibration certificate of this scale is attached in the appendices. Second, welding fume is generated and separated for a period of 30 minutes. After that, the concentration of fume

passing through the filter unit is measured for a period of 30 minutes, by collecting the filtered air onto a sampling filter. Next, fume is extracted without sampling for another 60 minutes, after which the airflow is recorded again and a second welding fume rate is determined. Both welding fume generation rated are used to calculate the average. That average value, together with the concentration values from the samples is used in the calculation to determine the unit's filtration efficiency.

The procedure above is performed twice, and the two results are used to calculate the average, the 95% one-sided confidence interval and the lower confidence limit value, in accordance to ISO 2602-1980.

3.2 Test setup in practice

3.2.1 Setup to determine welding fume generation rate

Figure 3-2 shows the sample mechanism to collect the generated fumes onto a glass fibre filter (manufacturer specification: Whatman, glass microfiber filter, GF/A 240 mm, Cat No 1820-240), in order to determine the fume generation rate.




Figure 3-2 Setup to determine the fume source emission rate

Fumes are generated by using a MIG/MAG welding machine together with an automated rotation drum, where to combination can create a continuous weld to generate a constant amount of welding fumes for longer periods of time.

To collect the welding fume onto the sample filter, a construction was made to place the filter in a holder, where the holder is connected to a side channel blower (not shown) to create the required negative pressure in order to capture all fumes at the welding point. This construction is able to extract all generated welding fume from the welding chamber for a period of 60 seconds.

3.2.2 <u>Setup to determine the filter unit separation efficiency</u>

The filter unit is placed in a test enclosure, where the inlet of the filter unit is connected to the extraction hood on the welding machine, by means of spiral ducting (\emptyset 160 mm) (see Figure 3-3). This upstream duct is equipped with a flow measuring sensor (Micatrone MFS-C-160 MM), connected to a pressure monitor, to measure the upstream air low of the filter unit. The upstream duct can be connected to the inlet of the test filter machine. Also see Figure 3-4 on page 10.



Figure 3-3 Overall picture of the complete test setup

Also the downstream duct is equipped with an airflow measuring sensor (Micatrone MFS-C-200 MM). The diameter of this duct is 200 mm. This duct further houses a measurement point for the downstream air sampling, and is connected to a fan (Plymovent FUA 3000, 1.1 kW, 3Ph, 400V 50 Hz).



Figure 3-4 MobileGo placed in the test cabin with the upstream duct connected to the inlet

3.2.3 <u>Sample taking of filtered air</u>

Samples have been taken using preweighted, 37mm quartz fiber filters. These filters have been bought at RPS¹. The samples have been taken using a rented, precalibrated pump, type: RPS Analyse, RX001. This pump has been set at RPS by an airflow of 20 liter/minute.

In order to achieve isokinetic sampling, specific sample inlet head have been made. These have been sized to achieve an inlet velocity in the sample inlet, based on 20 ltr/min, which equals the theoretical air velocity in the downstream air duct based on the measure airflow.

3.2.4 Airflow measurements and logging

During the tests, airflow measurements have been performed in both the upstream and downstream duct. The flow sensors (Micatrone MFS-C-XXX) have been connected to calibrated pressure monitors, of brand and type BLAUWE LIJN S4602 ST, serial numbers 036601686 and 036601600. The calibration certificated of these two monitors are added in the appendices. These pressure monitors fulfill the demands as prescribed in the NEN-EN-ISO 15012-1:2013. The resulting logs are stored for reference in a separate spreadsheet.

3.2.5 Other practical information

To assure sample taking and time recording during the welding sequences in the test, a datalogger has been connected to the welding machine setup. Both the drum as the welding machine itself have been

¹ RPS, Minervum 7002, 4817 ZL Breda

modified with sensors to check whether welding is active. In the welding machine itself, the wire throughput is checked, and the rotating drum is checked for continuous rotation. If either sensor detects a stall, the welding machine stops, and a datalogger records that. This means that each test is always performed with the exact same amount of welding time, and thus amount of fumes.

4. Measurement results

4.1Test 1

All data that was collected and processed is filed in a separate spreadsheet. This file is named: MobileGo IFA efficiency test 1 12092017.

This file shows, that during sampling, the average airflow through the unit is 814 m³/h. During the entire test the lowest measured airflow is 737 m³/h and does not drop below the minimum airflow of 500 m³/h.

The filter used for sampling in the downstream duct is known under reference FI1642-773.

Test number	12-09-2017-001	
Welding type	MAG	
Welding wire material	EN 440G3 Si1	
Wire diameter	1,2	mm
Wire speed	7,28	m/min
Welding voltage	30	V
Peak current	222	A
Normal current	170	A
Peak period	nb	ms
Peak frequency	nb	Hz
Shielding gas	80/20 Ar/CO ₂	
Flow rate shielding gas	14	l/Min
Distance tip to metal	20	mm
Drum diameter	390	mm
Welding speed	7	mm/sec
Flowrate	nb	M3/uur

4.1.1 Welding parameters

Table 4-1 Welding parameters test 1

	New filter	Polluted filter	Weight of		Calculated
			•		pollution
	weight	weight*	pollution	Welding	rate
	[mg]	[mg]	[mg]	time [s]	[mg/s]
	Before weld	ing test			
1	2449	2924	475	60	7,92
2	2434	2865	431	60	7,18
3	2445	2892	447	60	7,45
After welding test					
4	2449	2970	521	60	8,68
5	2455	2986	531	60	8 <i>,</i> 85

Determination of Fume Generation Rate 4.1.2

Average pollution rate before					
test					
7	7,52	[mg/s]			

4	2449	2970	521	60	8,68
5	2455	2986	531	60	8,85
6	2431	3017	586	60	9,77

Average p	pollution rate af	ter test
	9,10	[mg/s]

* filter weighted after 60s of

continuous welding

4.1.3 Determination of parameter for efficiency calculation

The following calculation method is used (from ISO-15012-1:2013):

$$\eta = \left(1 - \frac{\gamma_{\text{out}}}{\gamma_{\text{in}}}\right) \times 100\%$$
⁽¹⁾

where

$$\gamma_{\rm out} = \frac{m_{\rm s\,out}}{V_{\rm s\,out}} \,\rm mg/m^3 \tag{2}$$

$$\gamma_{\rm in} = \frac{m_{\rm in}}{V_{\rm in}} \,\mathrm{mg/m^3} \tag{3}$$

in which

 $m_{s out}$ is the mass of the welding fume particles on the sampling filter in the downstream air [mg];

is total mass of emitted welding fume from the source calculated from the average emission min rate multiplied by the measuring time [mg];

 $V_{\rm sout}$ is the total air volume that passes through the sampling filter in the downstream air [m³];

is the total air volume that passes through the separation equipment during the test [m³]. V_{in}

$$m_{in} = \left(\frac{7,52 \ [mg/s] + 9,10 \ [mg/s]}{2}\right) \times 60 \ \left[\frac{\sec}{\min}\right] \times 30 \ [min] = 14955 \ mg$$
$$V_{s \ out} = 30 \ [min] \ \times \ \frac{20 \ ltr/min}{1000} = 0,6 \ m^3$$

 V_{in} = average airflow during sampling² x sampling time = 814 m³/h x 30 min = 407 m³

4.1.4 Efficiency calculation

$$\gamma_{out} = \frac{m_{s out}}{V_{s out}} = \frac{0.06 \ [mg]}{0.6 \ [m^3]} = 0.10 \ [\frac{mg}{m^3}]$$

$$\gamma_{in} = \frac{m_{in}}{V_{in}} = \frac{14955 \ [mg]}{407 \ [m^3]} = 36.74 \ [\frac{mg}{m^3}]$$

$$\eta = \left(1 - \frac{\gamma_{out}}{\gamma_{in}}\right) \times 100\% = \left(1 - \frac{0.10}{36.74}\right) \times 100\% = 99.72\%$$

4.2 Test 2

All data that was collected and processed is filed in a separate spreadsheet. This file is named: MobileGo IFA efficiency test 2 13092017.

This file shows, that during sampling, the average airflow through the unit is 832 m³/h. During the entire test the lowest measured airflow is 721 m³/h and does not drop below the minimum airflow of 500 m³/h.

The filter used for sampling in the downstream duct is known under reference FI1642-771.

Test number	12-09-2017-002	
Welding type	MAG	
Welding wire material	EN 440G3 Si1	
Wire diameter	1,2	mm
Wire speed	7,28	m/min
Welding voltage	30	V
Peak current	222	A
Normal current	170	A
Peak period	Unknown	ms
Peak frequency	Unknown	Hz
Shielding gas	80/20 Ar/CO ₂	
Flow rate shielding gas	14	l/Min
Distance tip to metal	20	mm
Drum diameter	390	mm
Welding speed	7	mm/sec
Flowrate	nb	M3/uur

4.2.1 Welding parameters

Table 4-2 Welding parameters test 2

² Resulting from recorded air flow logs, also refer to chapter 3.2.4

New filter		Polluted filter	Weight of		Calculated pollution
	weight	weight*	pollution	Welding	rate
	[mg]	[mg]	[mg]	time [s]	[mg/s]
	Before weld	ing test			
1	2466	2946	480	60	8,00
2	2457	2934	477	60	7,95
З	2458	2937	479	60	7,98
After welding test					
4	2465	2940	475	60	7,92
5	2463	2970	507	60	8,45

Determination of Fume Generation Rate 4.2.2

Average pollution rate before					
test					
	7,98	[mg/s]			

4	2465	2940	475	60	7,92
5	2463	2970	507	60	8,45
6	2458	2970	512	60	8,53

Average	pollution rate af	ter test
	8,30	[mg/s]

* filter weighted after 60s of

continuous welding

4.2.3 Determination of parameter for efficiency calculation

The following calculation method is used (from ISO-15012-1:2013):

$$\eta = \left(1 - \frac{\gamma_{\text{out}}}{\gamma_{\text{in}}}\right) \times 100 \%$$
⁽¹⁾

where

$$\gamma_{\rm out} = \frac{m_{\rm sout}}{V_{\rm sout}} \,\mathrm{mg/m^3} \tag{2}$$

$$\gamma_{\rm in} = \frac{m_{\rm in}}{V_{\rm in}} \,\mathrm{mg/m^3} \tag{3}$$

in which

 $m_{s out}$ is the mass of the welding fume particles on the sampling filter in the downstream air [mg];

is total mass of emitted welding fume from the source calculated from the average emission min rate multiplied by the measuring time [mg];

 $V_{\rm sout}$ is the total air volume that passes through the sampling filter in the downstream air [m³];

is the total air volume that passes through the separation equipment during the test [m³]. V_{in}

$$m_{in} = \left(\frac{7,98 \,[mg/s] + 8,30 [mg/s]}{2}\right) \times 60 \,\left[\frac{\text{sec}}{\text{min}}\right] \times 30 [\text{min}] = 14650 \,\text{mg}$$
$$V_{s \,out} = 30 \,[min] \,\times \frac{20 \,ltr/min}{1000} = 0,6 \,m^3$$

 V_{in} = average airflow during sampling³ x sampling time = 832 m³/h x 30 min = 416 m³

4.2.4 Efficiency calculation

$$\gamma_{out} = \frac{m_{s out}}{V_{s out}} = \frac{0,08 \ [mg]}{0,6 \ [m^3]} = 0,13 \ [\frac{mg}{m^3}]$$

$$\gamma_{in} = \frac{m_{in}}{V_{in}} = \frac{14650 \ [mg]}{416 \ [m^3]} = 35,24 \ [\frac{mg}{m^3}]$$

$$\eta = \left(1 - \frac{\gamma_{out}}{\gamma_{in}}\right) \times 100\% = \left(1 - \frac{0,13}{35,62}\right) \times 100\% = 99,62\%$$

³ Resulting from recorded air flow logs, also refer to chapter 3.2.4

5. Calculation of final results and conclusion

5.1 Average efficiency $\eta_{average} = \frac{\eta_1 + \eta_2}{2} = \frac{99,72 + 99,62}{2} = 99,67\%$

5.2 95% one-sided confidence interval

$$\bar{x} = \frac{1}{n} \sum_{i=1}^{n} x_i = \frac{1}{2} (99,72 + 99,62) = 99,67\%$$

$$\frac{t_{0,95}}{\sqrt{n}} = 4,465^4$$

$$s = \sqrt{\frac{1}{n-1} \sum_{i=1}^{n} (x_i - \bar{x})^2} = \sqrt{\frac{1}{2-1} ((99,72 - 99,67)^2 + (99,62 - 99,67)^2)} = 0,071$$

$$m < \bar{x} + \frac{t_{0,95}}{\sqrt{n}}s < 99,67 + (4,465 \times 0,071) < 99,98\%$$

$$m > \bar{x} - \frac{\iota_{0.95}}{\sqrt{n}} s > 99,67 - (4,465 \times 0,071) > 99,35\%$$

5.3 Lower confidence limit value

$$m > \bar{x} - \frac{t_{0,95}}{\sqrt{n}} s > 99,67 - (4,465 \times 0,071) > 99,35\%$$

5.4 Conclusion

The MobileGo filterunit has a lower confidence limit value for the dust capturing efficiency of 99,35%, and may therefore be marked as W3 according to ISO 15012-1 2013.

⁴ From table on page 4, ISO 2602-1980 (E)

6. Literature

NEN-EN-ISO 15011-1:2009 (en) Health and safety in welding and allied processes - Laboratory method for sampling fume and gases - Part 1: Determination of fume emission rate during arc welding and collection of fume for analysis (ISO 15011-1:2009,IDT)

NEN-EN-ISO 15012-1:2013 (en) - Health and safety in welding and alliedprocesses - Equipment for capture and separation of welding fume - Part 1: Requirements for testing and marking of separation efficiency (ISO 15012-1:2013,IDT)

ISO 2602:1980 (en) Statistical interpretation of test results – Estimation of the mean – Confidence interval

Appendix A: Product Data Sheet of the MobileGo Extraction unit.

PLYM^{FJ}VENT[®]

clean air at work

MOBILEGO

MOBILE FILTER UNIT WITH HOSE TUBE ARM

The MobileGo is a mobile welding fume filter with built-in fan and a hose tube arm (EconomyArm). It contains a disposable filter package.

Thanks to the four transport wheels (two of which are swivel casters with brake), the MobileGo is suitable for use in relatively small facilities or near sources of pollution without a fixed location.

The MobileGo is an entry level extractor. It has been designed for the consumption of approx. 1 coil of solid wire or 7,5 kg (16.5 lbs) of electrodes per month and TIG welding.

APPLICATIONS

- The MobileGo is intended to be used for the following applications: • MIG-MAG/GMAW welding • grinding
- TIG welding
 polishing
- FCAW welding
 stick/MMAW welding

SPECIFICATIONS

SPECIFICATIONS	
Physical dimensions	and properties
Material (housing): • steel grade • steel grade no.	electro-zinc coated steel (according to DIN EN 10152) • DC01+ZE • 1.0330
Colour	yellow RAL 1004 grey RAL 7011
Weight (net), excl. arm	84 kg (185 lbs)
Mains cord: • type • length	• 3G1.5 • 6 m (20 ft)
Extraction arm	
Туре	EconomyArm (EA)
Material	hose tube
Diameter	Ø 160 mm (6.3 in.)
Hood opening	Ø 300 mm (11.8 in.)
Length: • EA-2 • EA-3	• 2 m (6.6 ft) • 3 m (9.8 ft)
Weight: • EA-2 • EA-3	• 11 kg (24.3 lbs) • 13 kg (28.7 lbs)
Filters	
Pre filter (cassette):	
 material 	 polyester
 filter surface 	 1 m² (10.8 ft²)
 filter classification 	 ISO Coarse 70% according to ISO 16890
 washable 	• no
Main filter (cassette):	
material	glass fibre
 filter surface 	 15 m² (161 ft²)

efficiency class	E12 according to
	EN 1822-1:2009
washable	• no
Welding fume class	1
W3	according to ISO 15012- 1:2013
Performance	
Fan type	radial
Extraction capacity (incl. extraction arm)	max. 850 m ³ /h (500 CFM)
Fan speed	2800 rpm
Noise level (according to ISO 3746)	67 dB(A)
Electrical data	·
Power consumption	1,1 kW (1.5 HP)
Available connection	 115V/1ph/50Hz (115)
voltages	 230V/1ph/50Hz (215)
Motor design	IEC
Energy efficiency	n.a. for single phase motors
Plug:	Type:
 115V/1ph/50Hz 230V/1ph/50Hz 	• none • F
Ambient and process	
Process temperature:	
• min.	 5°C (41°F)
 nom. 	 20°C (68°F)
• max.	• 70°C (158°F)
Max. relative humidity	90%
Suitable for outdoor use	no
Storage conditions	 5-45°C (41-113°F) relative humidity max. 80%
Options and accessor	
MobileGo-AC/2m (215)	MobileGo with an activated
MobileGo-AC/3m (215)	carbon filter instead of a HEPA filter
Scope of supply	
	on arm (pre-assembled; excl.
hose tube) - Hose tube - I	
	ncl. rubber collar – Extraction
hood - Hood collar with sa	fety mesh – Mounting material

Page 1/3

product data sheet

www.plymovent.com





 \sim

PLYM^{^{CI}VENT[°]}

clean air at work

Туре	MobileGo/2m		MobileGo/3m	
Connection voltage	115V/1ph/50Hz	230V/1ph/50Hz	115V/1ph/50Hz	230V/1ph/50Hz
Order information				
Article no.	0000111450	0000111449	0000111471	0000111470
 MobileGo-AC 		0000112350		0000112353
Number/package	1	1	1	1
Logistics data	•			
Gross weight (incl. pallet)	101 kg (223 lbs)		103 kg (227 lbs)	
Packing dimensions (incl. pallet)	800 x 1200 x 1650 mm (31.5 x 47.2 x 65.0 in.)		800 x 1200 x 2250 mm (31.5 x 47.2 x 88.6 in.)	
Max. number/pallet	1		1	
Harmonized Tariff Code	84213925		84213925	





Page 2/3

PLYM SVENT

clean air at work



Simple control | Service indicator (buzzer) monitors the airflow

APPROVALS/CERTIFICATES

CE	
RoHS	Directive 2011/65/EC (RoHS) valid as of 8 June 2011

Application restrictions

Application restrictions Do not use the product for the following applications or in the following dircumstances: jolishing applications in combination with grinding, weiging or any other application that generate sparks (fibres from polishing or abrazive flap disks are highly flammable and pose a high risk of fiber fiber when exposed to sparks) i aluminium laser outting i oil mist | heavy oil mist in weiding fume | arc-air gouging | estraction of aggressive fumes and gases (e.g. from aidd, from aikalane, from soldering paste containing lithlium) | extraction of hot gases (more than $70^{\circ}C/158^{\circ}$ F continuously) | grinding aluminum and magnesium | fame spraying | estraction of coment, saw dust, wood dust etc. | sucking cigarattes, cigars, olied tissues and other burning particles, objects and acids | explosive environments or explosive substances/gases

Product type	
Article no.	
Product category	
Version	

MobileGo refer to Order Information mobile filter units 25051B/F

Always check the latest version on www.plymovent.com

Page 3/3

Appendix B: Product Data Sheet of the MonoGo Extraction unit

V

PLYM VENT

clean air at work

MONOGO

STATIONARY FILTER UNIT WITH HOSE TUBE

ARM

The MonoGo is a stationary welding fume filter with built-in fan and a hose tube arm (EconomyArm). It contains a disposable filter package.

The MonoGo is an entry level extractor. It has been designed for the consumption of approx. 1 coil of solid wire or 7,5 kg/16.5 lbs of electrodes per month and TIG welding.

APPLICATIONS

The Mone	oGo is	intended	to b	e used	for the	
following	applic	ations:				

finishing

 MIG-MAG/GMAW welding grinding
 polishing

- TIG welding · FCAW welding
- stick/MMAW welding

SPECIFICATIONS

Physical dimensions	and properties
Material (housing):	electro-zinc coated steel
a shared sounds	(according to DIN EN 10152) • DC01+ZE
 steel grade steel grade no 	• DC01+2E • 1.0330
steel grade no.	
Colour	yellow RAL 1004
Weight (net), excl. arm	grey RAL 7011 78 kg (172 lbs)
Mains cord	
	not included
Extraction arm	
Туре	EconomyArm (EA)
Material	hose tube
Diameter	Ø 160 mm (6.3 in.)
Hood opening	Ø 300 mm (11.8 in.)
Length:	
• EA-2	 2 m (6.6 ft)
• EA-3	• 3 m (9.8 ft)
• EA-4	• 4 m (13.1 ft)
Weight:	
• EA-2	 11 kg (24.3 lbs)
• EA-3	 13 kg (28.7 lbs)
• EA-4	• 15 kg (33.1 lbs)
Filters	
Pre filter cassette:	
 material 	 polyester
 filter surface 	 1 m² (10.8 ft²)
 efficiency 	 G4 according to EN 779
 washable 	• no
HEPA filter cassette:	
 material 	glass fibre
 filter surface 	 15 m² (161 ft²)
 efficiency 	HEPA E12 according to
-	EN 1822:2009

washable	l	
	• no	
Welding fume class		
W3	according to ISO 15012-1:2013	
Performance		
Fan type	radial	
Extraction capacity (incl. extraction arm)	max. 850 m ³ /h (500 CFM)	
Fan speed	2800 rpm	
Noise level (according to ISO 3746)	67 dB(A)	
Electrical data		
Power consumption	1,1 kW (1.5 HP)	
Available connection voltages	 115V/1ph/50Hz (115) 115V/1ph/60Hz (116) 230V/1ph/50Hz (215) 	
Motor design	IEC	
Energy efficiency	n.a. for single phase motors	
Ambient and process conditions		
Process temperature: • min. • nom. • max.	• 5°C (41°F) • 20°C (68°F) • 70°C (158°F)	
Max. relative humidity	90%	
Suitable for outdoor use	no	
Storage conditions	 5-45°C (41-113°F) relative humidity max. 80% 	
Scope of supply		
Stationary filter unit, incl. fan and wall bracket – Extraction arm (pre-assembled; excl. hose tube) – Hose tube – Hose clamp (2) – Rotating flange – Arm swivel ring, incl. rubber collar – Extraction hood – Hood collar with safety mesh – Mounting material – Switch box		

Page 1/3


product data sheet


www.plymovent.com

PLYM^EVENT[®]

clean air at work

Туре	MonoGo/2m	MonoGo/3m	MonoGo/4m
Order information			
Connection voltage	Article no.	Article no.	Article no.
115V/1ph/50Hz	0000111456	0000111477	0000111489
115V/1ph/60Hz	0000111457	0000111478	0000111490
230V/1ph/50Hz	0000111455	0000111476	0000111488
Number/package	1	1	1
Logistics data			
Gross weight (incl. pallet)	103 kg (227 lbs)	106,5 kg (235 lbs)	107,5 kg (237 lbs)
Packing dimensions (incl. pallet)	800 x 1200 x 1750 mm (31.5x47.2x68.9 in.)	800 x 1200 x 2250 mm (31.5x47.2x88.6 in.)	800 x 1200 x 2250 mm (31.5x47.2x88.6 in.)
Max. number/pallet	2	2	2
Harmonized Tariff Code	84213925	84213925	84213925





Page 2/3



clean air at work

FEATURES & BENEFITS



Compact design



Service indicator (buzzer)

APPROVALS/CERTIFICATES

Directive 2011/65/EC (RoHS) valid as of 8 June 2011

Application restrictions Do not use the product for the following applications or in the following circumstances: pollshing applications in combination with grinding, welding or any other application that generate sparks (fibres from polishing or abrasive flap disks are highly flammable and pose a high risk of fiber fires when exposed to sparks) | aluminium laser cutting | of mist | heavy oil mist in welding fume | arc-air gouging | extraction of agressive fumes and gases (e.g. from adds, from alkaline, from soldering paste containing lithium) | extraction of hot gases (more than 70°C/158°F continuously) | grinding aluminum and magnesium | flame spraying | extraction of comment, saw dust, wood dust etc. | sucking cigarettes, cigars, olled tissues and other burning particles, objects and acids | explosive environments or explosive substances/gases

Produ	act ty	pe	
Artic	e no		
Versi	uct ca on	ste	g any

MonoGo refer to Order information stationary fliter units 280917/G

Always check the latest version on www.plymovent.com

Page 3/3

Appendix C: Result weight determination sample filter test 1

Code Parameter	Absoluut	Relatief(1)	
Opmerking	-		
Monstergegevens afkomstig van	Opdrachtgever		
Soort monster	Kwartsvezel filter (37 mm)		
Filternummer	FI1642-773		
Volume (I)	600		
Meettijd (min)	30		
Monsternummer opdrachtgever	-		
Datum monstername	-	W www.rps.nl	
Adres monstername	W3 testopstelling	E analyse@rps.nl	
Monsternamepunt	-	T 088 99 04 730	
	1812 RK Alkmaar		
	Koraalstraat 9	Postbus 3440 4800 DK Breda	
Opdrachtgever	Plymovent Group BV	4817 ZL Breda	
Ordernummer opdrachtgever	Onbekend	Minervum 7002	
Monsternummer RPS	17-181376	RPS analyse by	
Datum order	13-09-2017	222	
Rapportnummer: 1709-1674_0	1		
RPS	Analyse certificaa	Datum rapportage 20-09-2	2017
		V2803	17_1

	Stof gravimetrisch				
Q	Stof	0,06	mg	0,10	mg/m³

Toelichting: '--' Het analyseresuitaat is kleiner dan de rapportagegrens van de desbetrefiende methode. '--' Het meetresuitaat valt boven het kalibratie- of werkgebied van de methode. (s): semi kwantitaater Code E: De analyse is uitgevoerd door een extern laboratorium. Code C: De analyse betreft een RvA Testen geaccrediteerde verrichting (registratienummer L192). (1) Deze analyse resultaen zijn berekend op basis van het (evt. door de opdrachtgever) opgegeven volume of meettijd en vallen niet onder de scope van accreditatie L192. n.t.b. Niet te beoordelen I.v.m. groel van overdge micro-organismen Dit certificaat meg uitsluitend in zijn geheel worden gereptroduceerd waarbij alleen aan het originele analysecertificaat rechten kunnen worden ontieend. De resultaen hebben uitsluitend betrekking op ehet aangeboden monster.

De resultaten hebben ultsluitend betrekking op het aangeboden monster. Meetonzekerheld op aanvraag.

Esther Ullings

Projectcoördinator

Pagina 1/2

RPS analyse by KvK 20059540 BTW NL0089.00.620.B.01

Nederland I Engeland I Ierland I Rusland I Verenigde Staten I Canada I Australië I Zuldoost-Azlë I Brazilië I Midden-Oosten I Afrika

Appendix D: Result weight determination sample filter test 2

				V280317_1
	RPS	Analyse certificaat	Datum rapportage	15-09-2017
Rapportnu	mmer: 1709-1935_01			
Datum or	der	14-09-2017	DDC	
Monstern	ummer RPS	17-182606	RPS analys	e bv
Ordernummer opdrachtgever		900448	Minervum 7002	
Opdracht	gever	Plymovent Group BV	4817 ZL Breda	
		Koraalstraat 9	Postbus 3440 4800 DK Breda	
		1812 RK Alkmaar		
Monstern	amepunt	MobileGo test 2	T 088 99 04 730	
Adres mo	onstername	Koraalstraat Alkmaar	E analyse@rps.	nl
Datum m	onstername	-	W www.rps.nl	
Monstern	ummer opdrachtgever	2		
Meettijd (min)	30		
Volume (I)		-		
Filternummer		FI1642-771		
Soort monster		Kwartsvezel filter (37 mm)		
Monstergegevens afkomstig van		Opdrachtgever		
Opmerking		-		
Code	Parameter	Absoluut		
	Stof gravimetrisch			
Q	Stof	0,08 mg		

Toelichting: '<' Het analyseresultaat is kielner dan de rapportagegrens van de desbetreffende methode. '>' Het meetresultaat valt boven het kalibratie- of werkgebied van de methode. (s): semi kwantitatief Code E: De analyse is uitgevoerd door een extern laboratorium. Code Q: De analyse betreft een RvA Testen geacorcefiteerde verrichting (registratienummer L192). (1) Deze analyse betreft een RvA Testen geacorcefiteerde verrichting (registratienummer L192). (1) Deze analyse resultaten zijn berekend op basis van het (evt. door de opdrachtgever) opgegeven volume of meettijd en vallen niet onder de scope van accreditatie L192. n.t.b. Niet be beoordelen I.v.m. groel van overlige micro-organismen Dit certificaat mag uitsluitend in zijn geheel worden gereproduceerd waarbij alleen aan het originele analyseecertificaat recten kunnen worden ontbiend. De resultaten hebben uitsluitend betrekking op het aangeboden monster. Meetonzekerheid op aanvraag.

Esther Ulings Projectcoordinator

Pagina 1/2

RPS analyse by KvK 20059540 BTW NL0089.00.620.B.01

Nederland i Engeland i leriand i Rusiand i Verenigde Staten i Canada i Australië i Zuldoost-Azië i Brazilië i Midden-Oosten i Afrika

Appendix E: Calibration certificate of pressure monitor 1

Dhr. var Postbus ats 1800 G. Drukmei EURO-II BLAUW 0366016 mmer 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienuur vertificaatnummer 416122 iboratorium worden onde 23 °C ± : icchtigheid 50 %rh a 1000 hP.	s 9350 J ALKMAAR Iter INDEX IE LIJN S460 686 Instemming m ov. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh Pa ± 50 hPa	12-ST et onderstaand kalibrator (PPC	3/PPC4) Ielen:	12
Plymove Dhr. var Postbus ats 1800 GJ Drukmel EURO-II BLAUW 0366016 immer 188834 komst KWS s gebruik gemaakt van o k kalibrator met serienum xertificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP	n Rhee s 9350 J ALKMAAR iter INDEX /E LIJN S460 686 instemming m b.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh Pa ± 50 hPa	12-ST et onderstaand kalibrator (PPC	3/PPC4) Ielen:	
Dhr. var Postbus ats 1800 G. Drukmei EURO-II BLAUW 0366016 mmer 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienuur vertificaatnummer 416122 iboratorium worden onde 23 °C ± : icchtigheid 50 %rh a 1000 hP.	n Rhee s 9350 J ALKMAAR iter INDEX /E LIJN S460 686 instemming m ov. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh Pa ± 50 hPa	12-ST et onderstaand kalibrator (PPC	3/PPC4) Ielen:	
Dhr. var Postbus ats 1800 G. Drukmei EURO-II BLAUW 0366016 mmer 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienuur vertificaatnummer 416122 iboratorium worden onde 23 °C ± : icchtigheid 50 %rh a 1000 hP.	n Rhee s 9350 J ALKMAAR iter INDEX /E LIJN S460 686 instemming m ov. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh Pa ± 50 hPa	12-ST et onderstaand kalibrator (PPC	3/PPC4) Ielen:	
Postbus ats 1800 G. Drukmel EURO-I BLAUW 0366016 immer 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum sertificaatnummer 416122 iboratorium worden onde 23 °C ± : icchtigheid 50 %rh a 1000 hP m zijn weergegeven op d	s 9350 J ALKMAAR Iter INDEX IE LIJN S460 686 Instemming m ov. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh Pa ± 50 hPa	92-ST et onderstaand kalibrator (PPC kalibratiemidd	3/PPC4) Ielen:	
ats 1800 GJ Drukmel EURO-II BLAUW 0365016 mmer 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum sertificaatnummer 416122 iboratorium worden onde 23 °C ± : schtigheid 50 %rh a 1000 hP	J ALKMAAR iter INDEX E LIJN S460 686 sstemming mo v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh °a ± 50 hPa	92-ST et onderstaand kalibrator (PPC kalibratiemidd	3/PPC4) Ielen:	
EURO-II BLAUW 0366016 0366016 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienuur sertificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP.	NDEX /E LIJN S460 686 nstemming m o.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh °a ± 50 hPa	et onderstaand kalibrator (PPC kalibratiemidd	3/PPC4) Ielen:	
EURO-II BLAUW 0366016 0366016 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienuur sertificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP.	NDEX /E LIJN S460 686 nstemming m o.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh °a ± 50 hPa	et onderstaand kalibrator (PPC kalibratiemidd	3/PPC4) Ielen:	
BLAUW 0366016 immer 188834 komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum vertificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP	rE LIJN S460 686 nstemming m ov. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa	et onderstaand kalibrator (PPC kalibratiemidd	3/PPC4) Ielen:	
mmer 188834 komst KWS gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum xertificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP	nstemming mo o.v. een drukk onderstaande nmer 1136 21 (RvA) 21 (RvA) erstaande om 3 °C ± 20 %rh a ± 50 hPa	kalibrator (PPC	3/PPC4) Ielen:	
komst KWS s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum xertificaatnummer 416122 iboratorium worden onde 23 °C ± 1 ichtigheid 50 %rh a 1000 hP en zijn weergegeven op d	nstemming m ovv. een drukk onderstaande nmer 1136 21 (RvA) 21 (RvA) erstaande om 3 °C ± 20 %rh a ± 50 hPa	kalibrator (PPC	3/PPC4) Ielen:	
s gekalibreerd in overeen aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum vertificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP m zijn weergegeven op d	o.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa	kalibrator (PPC	3/PPC4) Ielen:	
aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum ærtificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP m zijn weergegeven op d	o.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa	kalibrator (PPC	3/PPC4) Ielen:	
aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum ærtificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP m zijn weergegeven op d	o.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa	kalibrator (PPC	3/PPC4) Ielen:	
aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum ærtificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP m zijn weergegeven op d	o.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa	kalibrator (PPC	3/PPC4) Ielen:	
aanbieden van druk m.b s gebruik gemaakt van o k kalibrator met serienum ærtificaatnummer 416122 iboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP m zijn weergegeven op d	o.v. een drukk onderstaande nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa	kalibrator (PPC	3/PPC4) Ielen:	
k kalibrator met serienum vertificaatnummer 416122 uboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP en zijn weergegeven op d	nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa			
k kalibrator met serienum vertificaatnummer 416122 uboratorium worden onde 23 °C ± : ichtigheid 50 %rh a 1000 hP en zijn weergegeven op d	nmer 1136 21 (RvA) erstaande om 3 °C ± 20 %rh 2a ± 50 hPa			
boratorium worden onde 23 °C ± : chtigheid 50 %rh ± 1000 hP n zijn weergegeven op d	erstaan de om 3 °C ± 20 %rh ?a ± 50 hPa	ngevingscondit	ies gehandhaafd:	
23 °C ± : chtigheid 50 %rh ± 1000 hP n zijn weergegeven op d	3 °C ± 20 %rh °a ± 50 hPa	ngevingscondit	ies gehandhaafd:	
chtigheid 50 %rh ± 1000 hP n zijn weergegeven op d	± 20 %rh ?a ± 50 hPa			
1000 hP	Pa±50 hPa			
n zijn weergegeven op d				
	la ualable d'			
weergegeven op dit kali	maakt van de	e bereiken en s	en van de kolom pecificaties van he	t
lelen van EURO-INDEX	b.v. zijn herle	eidbaar naar (i	nter-)nationale	
IJssel, 08-08-2017				
Jasel, 00-08-2017				
\rightarrow				
1.				
at Manager				
liarina certificani is inecessor				
ificaat mogen slechts worden		A	PC	
kregen schriftelijke toestemming				
wegen schnitelijke toestenisting	9			
010	st Manager olledige certificaat is toegestaan tificaat mogen siechts worden	st Manager	st Manager	oliedige certificaal is toegeslaan.

Appendix F: Calibration certificate of pressure monitor 2

02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mel en certificaatnumm	Plymovent Manufacturing BV Dhr. Crezee Postbus 9350 1800 GJ ALKMAAR Drukmeter EURO-INDEX BLAUWE LIJN S4602-ST 036601600 180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) wakt van onderstaande kalibratiemiddelen: er erienummer 1136 ier 4161221 (RvA)	
entie van ode en plaats nstrument aat ummer e-artikelnummer e-overeenkomst 2016 2017 2016 2017 strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mel en certificaatnumm kalibratielaboratorium wo	Dhr. Crezee Postbus 9350 1800 GJ ALKMAAR Drukmeter EURO-INDEX BLAUWE LIJN S4602-ST 036601600 180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) wakt van onderstaande kalibratiemiddelen: is erienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
ode en plaats nstrument aat ummer e-artikelnummer e-overeenkomst 2016 2017 2017 atrument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mei en certificaatnumm kalibratielaboratorium wo	Postbus 9350 1800 GJ ALKMAAR Drukmeter EURO-INDEX BLAUWE LIJN S4602-ST 038601600 180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) wakt van onderstaande kalibratiemiddelen: i serienummer 1136 ter 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
nstrument aat ummer e-artikelnummer e-overeenkomst 2016 2017 strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mei en certificaatnumm kalibratielaboratorium wo	1800 GJ ALKMAAR Drukmeter EURO-INDEX BLAUWE LJIN S4602-ST 036601600 180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) wakt van onderstaande kalibratiemiddelen: serienummer 1136 ter 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
aat ummer e-artikelnummer e-overeenkomst 2016 2017 strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mei en certificaatnumm kalibratielaboratorium wo	EURO-INDEX BLAUWE LIJN S4602-ST 036601600 180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) wakt van onderstaande kalibratiemiddelen: er erienummer 1136 er 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
aat ummer e-artikelnummer e-overeenkomst 2016 2017 strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mei en certificaatnumm kalibratielaboratorium wo	BLAUWE LIJN S4602-ST 036601600 180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) wakt van onderstaande kalibratiemiddelen: serienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
e-artikelnummer e-overeenkomst 2016 2017 strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mei en certificaatnumm kalibratielaboratorium wo	036601600 180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) wakt van onderstaande kalibratiemiddelen: serienummer 1136 ler 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
e-artikelnummer e-overeenkomst 2016 2017 strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mei en certificaatnumm kalibratielaboratorium wo	180103 KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) ekkt van onderstaande kalibratiemiddelen: serienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
e-overeenkomst 2016 2017 atrument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mel en certificaatnumm kalibratielaboratorium wo	KWS n overeenstemming met onderstaande methoden: druk m.b.v. een drukkalibrator (PPC3/PPC4) aakt van onderstaande kalibratiemiddelen: serienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
2017 trument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator me en certificaatnumm kalibratielaboratorium wo	druk m.b.v. een drukkalibrator (PPC3/PPC4) aakt van onderstaande kalibratiemiddelen: I serienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mel en certificaatnumm kalibratlelaboratorium wo	druk m.b.v. een drukkalibrator (PPC3/PPC4) aakt van onderstaande kalibratiemiddelen: I serienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
strument is gekalibreerd i 02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mel en certificaatnumm kalibratlelaboratorium wo	druk m.b.v. een drukkalibrator (PPC3/PPC4) aakt van onderstaande kalibratiemiddelen: I serienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
02 Het aanbieden van kalibratie is gebruik gema 0 Druk kalibrator mel en certificaatnumm kalibratielaboratorium wo	druk m.b.v. een drukkalibrator (PPC3/PPC4) aakt van onderstaande kalibratiemiddelen: I serienummer 1136 ier 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
0 Druk kalibrator me en certificaatnumm kalibratielaboratorium wo	l serienummer 1136 ler 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
en certificaatnumm	er 4161221 (RvA) rden onderstaande omgevingscondities gehandhaafd:	
ratuur		
enances of the state of the second state of th	23 °C ± 3 °C	
ve luchtvochtigheid eterdruk	50 %rh ± 20 %rh 1000 hPa ± 50 hPa	
Binnen Specificaties) is g	even op de volgbladen. Bij het bepalen van de kolom sbruik gemaakt van de bereiken en specificaties van h op dit kalibratiecertificaat.	et
bratiemiddelen van EUR arden.	O-INDEX b.v. zijn herleidbaar naar (inter-)nationale	
aan den IJssel, 30-11-2	016	
AZ		
10 >		
INDEX b.v.		
de Bruin		
sche Dienst Manager		
tie van het volledige gertificaat is	logestaan.	
n van het certificaat mogen slech	ts worden	
uceerd na verkregen schriftelijke	toestemming A EURC	
	toestemming	
	arden. aan den IJssel, 30-11-2 INDEX b.v. de Bruin sche Dienst Manager lie van het volledige certificaat is van het certificaat mogen slecht	is aan den IJssel, 30-11-2016 MDEX b.v. de Bruin sche Dienst Manager lie van het volledige certificaat is toegestaan. van het oertificaat mogen slechts worden cered na verkregen schriftigke toestemming

Appendix G: Calibration certificate of precision scale



Cooperation wederzijdse erkenning van de kalbreerbewijzen. De gebruiker draagt de verantwoordelijkheid voor het herhalen van het kalibreren binnen gepaste tijd. 5

Dieser Kalibrierschein darf nur vollständig und unverändert weiterverbreitet werden. Auszüge oder Änderungen bedürfen der Genehmigung sowohl der Deutschen Akkreditierungsstelle GmbH als auch des ausstellenden Kalibrierlaboratoriums, Kalibrierscheine ohne Unterschrift haben keine Gültigkeit.

Dit kalibreerbewijs mag alleen in zijn volledigheid en onveranderd verspreid worden. Uittreksels of veranderingen moeten door zowel de accrediteringsdienst van de Deutsche Akkreditierungsstelle GmbH als ook door het kalibreerlaboratorium dat het bewijs aflevert, goedgekeurd worden. Kalibreerbewijzen zonder onderschrift zijn niet geldig.

2 allon 4 d A			
ion in	Datum	Leiter des Kalibrierlaboratoriums	Bearbeiter //
Co to Co	Datum	Hoofd van het kalibreerleboratorium	Verantwoordelijke medewerker
0 04 00 2		112 Marcha	1
S 19408-01-00 2		191101109	Tiller
1000 00	19.12.2016	Otto Grunenberg	Frank Kleißberg
- 200	10.12.2010	ene energy	/
AERN B		. //	
			Archiv: 00478389

KERN & Sohn GmbH, Ziegelei 1, D-72336 Balingen, Germany Sec: [f149e] Phone +49-7433-99330, Fax +49-7433-9933-149 QXC37 (rev16)

26096373

Anzahl der Seiten des Kalibrierscheines

Aantal pagina's van het ijkcertificaat Datum der Kalibrierung 19.12.2016

Auftragsnummer Ordern

Datum van de ijking

een